SIEMENS

Data sheet 3UG4618-1CR20



!!! product phase-out !!! The preferred successor type is 3UG5618-1CR20 phase sequence phase failure 3x160-690 V screw digital monitoring relay for 3-phase voltage with N-conductor automatic phase sequence correction phase failure 3 x 90 to 400 V 50 to 60 Hz AC undervoltage and overvoltage 90-400 V hysteresis 1-20 V OFF delay 0-20 s asymmetry 0-20% 1 CO for phase correction 1 CO for power system faults screw terminal

Figure similar

product brand name	SIRIUS
product designation	Network monitoring relay with digital setting
design of the product	5 functions
product type designation	3UG4
General technical data	
product function	Phase monitoring relay
display version LED	No
design of the display	LCD
insulation voltage for overvoltage category III according to IEC 60664	
with degree of pollution 3 rated value	690 V
degree of pollution	3
type of voltage	
for monitoring	AC
of the control supply voltage	AC
surge voltage resistance rated value	6 kV
protection class IP	IP20
shock resistance according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms
vibration resistance according to IEC 60068-2-6	1 6 Hz: 15 mm, 6 500 Hz: 2g
mechanical service life (operating cycles) typical	10 000 000
electrical endurance (operating cycles) at AC-15 at 230 V typical	100 000
thermal current of the switching element with contacts maximum	5 A
reference code according to IEC 81346-2	K
relative repeat accuracy	1 %
Substance Prohibitance (Date)	05/01/2012
SVHC substance name	Lead - 7439-92-1 Lead monoxide (lead oxide) - 1317-36-8
Product Function	
product function	
 undervoltage detection 	Yes
 overvoltage detection 	Yes
 phase sequence recognition 	Yes
phase failure detection	Yes
asymmetry detection	Yes
 overvoltage detection 3 phase 	Yes
 undervoltage detection 3 phases 	Yes
 voltage window recognition 3 phase 	Yes
 adjustable open/closed-circuit current principle 	No

• auto-RESET	Yes
Control circuit/ Control	
control supply voltage at AC	
• at 50 Hz rated value	90 400 V
at 60 Hz rated value	90 400 V
operating range factor control supply voltage rated value at	
AC at 50 Hz	
• initial value	1
• full-scale value	1
operating range factor control supply voltage rated value at	
AC at 60 Hz	
initial value	1
full-scale value	1
Measuring circuit	
measurable voltage at AC	90 400 V
adjustable response delay time	
with lower or upper limit violation	0.1 20 s
response time maximum	450 ms
accuracy of digital display	+/-1 digit
Precision	
relative metering precision	5 %
Auxiliary circuit	
number of NC contacts delayed switching	0
number of NO contacts delayed switching	0
number of CO contacts	
for auxiliary contacts	2
delayed switching	2
operating frequency with 3RT2 contactor maximum	5 000 1/h
Main circuit	
number of poles for main current circuit	3
ampacity of the output relay at AC-15	. •
• at 250 V at 50/60 Hz	3 A
• at 400 V at 50/60 Hz	3 A
ampacity of the output relay at DC-13	
• at 24 V	1A
• at 125 V	0.2 A
• at 250 V	0.1 A
operational current at 17 V minimum	5 mA
continuous current of the DIAZED fuse link of the output	4 A
relay	70
Electromagnetic compatibility	
conducted interference	
due to burst according to IEC 61000-4-4	2 kV
due to conductor-earth surge according to IEC 61000-4-5	2 kV
due to conductor-conductor surge according to IEC	1 kV
61000-4-5	
field-based interference according to IEC 61000-4-3	10 V/m
electrostatic discharge according to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Galvanic isolation	
galvanic isolation	
 between input and output 	Yes
 between the outputs 	Yes
 between the voltage supply and other circuits 	Yes
Connections/ Terminals	
product component removable terminal for auxiliary and control circuit	Yes
type of electrical connection	screw terminal
type of connectable conductor cross-sections	
Solid	1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²)
	1x (0.5 4.0 milr), 2x (0.5 2.5 milr) 1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²)
 finely stranded with core end processing for AWG cables solid 	
	2x (20 14)
for AWG cables stranded	2x (20 14)

connectable conductor cross-section	
• solid	0.5 4 mm²
finely stranded with core end processing	0.5 2.5 mm²
AWG number as coded connectable conductor cross section	
• solid	20 14
stranded	20 14
tightening torque with screw-type terminals	0.8 1.2 N·m
Installation/ mounting/ dimensions	
mounting position	any
fastening method	snap-on mounting
height	102 mm
width	22.5 mm
depth	91 mm
required spacing	
 with side-by-side mounting 	
— forwards	0 mm
— backwards	0 mm
— upwards	0 mm
— downwards	0 mm
— at the side	0 mm
 for grounded parts 	
— forwards	0 mm
— backwards	0 mm
— upwards	0 mm
— at the side	0 mm
— downwards	0 mm
• for live parts	
— forwards	0 mm
— backwards	0 mm
— upwards	0 mm
— downwards	0 mm
— at the side	0 mm
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
during operation	-25 +60 °C
during storage	-40 +85 °C
during transport	-40 +85 °C
Approvals Certificates	

General Product Approval





Confirmation







EMV Test Certificates Marine / Shipping



<u>KC</u>

Type Test Certificates/Test Report

Special Test Certificate





other Railway Environment

Confirmation Special Test Certificate



Environmental Confirmations

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4618-1CR20

Cax online generator

 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3UG4618-1CR20}$

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UG4618-1CR20


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UG4618-1CR20&lang=en

Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3UG4618-1CR20/manual





last modified:

4/8/2024