### Data Sheet | Item Number: 750-831 Controller BACnet/IP

https://www.wago.com/750-831

**DISCONTINUED:** 15.12.2019



The 750-831 BACnet/IP Controller connects the WAGO I/O System to the BACnet protocol and supports the B-BC BACnet device profile per DIN EN ISO 16484-5. It communicates with other BACnet devices via BACnet/IP.

The controller provides the three following functionalities:

- 1. Native server: For each channel, appropriate BACnet objects are generated automatically for the digital and analog I/O modules that are connected to the controller.
- 2. Application server: Other supported BACnet objects can be created via IEC 61131-3 programming environment and made available to a BACnet network.
- 3. Application client: Using the client functionality, objects and their properties can be accessed by other BACnet devices.
- Two ETHERNET interfaces and an integrated switch allow the fieldbus to be wired in a line topology, eliminating the need for additional network devices, such as switches or hubs. Both interfaces support autonegotiation and Auto-MDI(X).
- The DIP switch configures the last byte of the IP address and may be used for IP address assignment.
- An integrated Webserver provides configuration options to the user, while displaying the controller's status information.
- The device is programmable in accordance with IEC 61131-3, is multitasking-capable and features a battery-backed RTC.
- 1 MB of data memory is available.
- The 750-831 Controller is equipped with a removable memory card slot. A memory card can be used to transfer device parameters or files (e.g., boot files) from one controller to another. The memory card can be accessed via FTP and be used as an additional drive.
- The controller can process a maximum of 1000 simple BACnet objects. The actual number that can be implemented in the project can be reduced
  with complex object types. Start-up and configuration of the BACnet networks is performed using the WAGO BACnet Configurator's Windows software.

Technical data	
Communication	BACnet/IP Modbus (TCP, UDP) ETHERNET
ETHERNET protocols	HTTP BootP DHCP DNS SNTP FTP SNMP
/isualization	Web-Visu
CPU	32 bits
Programming languages per IEC 61131-3	Instruction List (IL) Ladder Diagram (LD) Function Block Diagram (FBD) Continuous Function Chart (CFC) Structured Text (ST) Sequential Function Chart (SFC)
Programming environment	WAGO-I/O-PRO V2.3 (based on CODESYS V2.3)
Configuration options	WAGO-I/O-CHECK BACnet Configurator Web-Based Management
Baud rate (communication/fieldbus 1)	10/100 Mbit/s
Baud rate	10/100 Mbit/s
Transmission medium (communication/fieldbus)	Twisted pair S-UTP; 100 $\Omega$ ; Cat. 5; 100 m maximum cable length
Transmission performance	Class D per EN 50173
nternal memory (flash)	4.5 MB
Program memory	1024 KB
Data memory	1024 KB
Non-volatile software memory	28 KB
Type of memory card	SD and SDHC up to 32 GB (all guaranteed properties only valid with the WAGO 758-879/000-001 Memory Card)
Memory card slot	Push-push mechanism; cover lid (sealable)
Number of modules per node (max.)	99
Number of modules without a bus extension (max.)	64
nput and output process image (fieldbus) max.	1020 words/1020 words

# Data Sheet | Item Number: 750-831 https://www.wago.com/750-831



Technical data	
Indicators	LED (LINK/ACT) green: Network connection via ports 1 2; LED (MS/BT, NS) red/green: Status of node/BACnet, network; LED (I/O, USR) red/green/orange: Local data bus status, status programmable by user; LED (A, B) green: Status of system power supply, field supply
Supply voltage (system)	24 VDC (-25 +30 %); via pluggable connector (CAGE CLAMP® connection)
Input current (typ.) at nominal load (24 V)	500 mA
Power supply efficiency (typ.) at nominal load (24 V)	90 %
Current consumption (5 V system supply)	450 mA
Total current (system supply)	1700 mA
Supply voltage (field)	24 VDC (-25 +30 %); via power jumper contacts
Current carrying capacity (power jumper contacts)	10 A
Number of outgoing power jumper contacts	3
Isolation	500 V system/field
WSPCert certification	ISO 16484-5:2012

Connection data	
Connection technology: communication/fieldbus	BACnet/IP: 2 x RJ-45; Modbus (TCP, UDP): 2 x RJ-45
Connection technology: system supply	2 x CAGE CLAMP®
Connection technology: field supply	6 x CAGE CLAMP®
Connection type 1	System/field supply
Solid conductor	0.08 2.5 mm <sup>2</sup> / 28 14 AWG
Fine-stranded conductor	0.08 2.5 mm <sup>2</sup> / 28 14 AWG
Strip length	89 mm / 0.31 0.35 inches
Connection technology: device configuration	1 x Male connector; 4-pole

Environmental requirements	
Ambient temperature (operation)	0 +55 °C
Ambient temperature (storage)	-40 +85 °C
Protection type	IP20
Pollution degree	2 per IEC 61131-2
Operating altitude	without temperature derating: 0 2000 m; with temperature derating: 2000 5000 m (0.5 K/100 m); 5000 m (max.)
Relative humidity (without condensation)	95 %
Mounting position	any
Mounting type	DIN-35 rail
Vibration resistance	4g per IEC 60068-2-6
Shock resistance	15g per IEC 60068-2-27
EMC immunity to interference	per EN 61000-6-2
EMC emission of interference	per EN 61000-6-3
Exposure to pollutants	per IEC 60068-2-42 and IEC 60068-2-43
Fire load	3.67 MJ
Permissible $\mathrm{H_2S}$ contaminant concentration at a relative humidity 75 %	10 ppm
Permissible SO <sub>2</sub> contaminant concentration at a relative humidity 75 %	25 ppm

## Data Sheet | Item Number: 750-831

https://www.wago.com/750-831



#### Approvals / Certificates

#### General approvals



Approval	Standard	Certificate Name
EAC Brjansker Zertifizierungs- stelle	TP TC 020/2011	EAC RU C-DE.AM02. B.00087/19
UL UL International Nether- lands B.V. (ORDINARY LO- CATIONS)	UL 508	E175199 Sec.1

#### Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Conformity WAGO GmbH & Co. KG	-	-

#### Approvals for marine applications



Approval	Standard	Certificate Name
DNV DNV GL SE	DNV-CG-0339,Aug.2021	TAA0000194

#### Protocol and fieldbus specific certificates



Approval	Standard	Certificate Name
BACnet WSP Cert	-	BACnet Listing Information BTL-30021

Subject to changes. Please also observe the further product documentation!

Page 3/3 Version 24.02.2024