SIEMENS

Data sheet 6EP1334-1LB00



SITOP PSU100L/1AC/24VDC/10A

SITOP PSU100L 24 V/10 A Stabilized power supply input: 120/230 V AC, output: DC 24 V/10 A

| input | | |
|--|---|--|
| type of the power supply network | 1-phase AC | |
| supply voltage at AC | Set by means of selector switch on the device | |
| supply voltage | 120 V/230 V | |
| input voltage 1 at AC | 93 132 V | |
| input voltage 2 at AC | 187 264 V | |
| wide range input | No | |
| overvoltage overload capability | 2.3 × Vin rated, 1.3 ms | |
| buffering time for rated value of the output current in the event of power failure minimum | 20 ms | |
| operating condition of the mains buffering | at Vin = 93/187 V | |
| line frequency | 50/60 Hz | |
| line frequency | 47 63 Hz | |
| input current | | |
| at rated input voltage 120 V | 4.1 A | |
| at rated input voltage 230 V | 2 A | |
| current limitation of inrush current at 25 °C maximum | 65 A | |
| duration of inrush current limiting at 25 °C | | |
| • typical | 3 ms | |
| I2t value maximum | 3.3 A²·s | |
| fuse protection type | T 6.3 A/250 V (not accessible) | |
| fuse protection type in the feeder | Recommended miniature circuit breaker: from 10 A characteristic C | |
| output | | |
| voltage curve at output | Controlled, isolated DC voltage | |
| output voltage at DC rated value | 24 V | |
| output voltage | | |
| at output 1 at DC rated value | 24 V | |
| output voltage adjustable | Yes; via potentiometer | |
| adjustable output voltage | 22.8 26.4 V | |
| relative control precision of the output voltage | | |
| on slow fluctuation of input voltage | 0.1 % | |
| on slow fluctuation of ohm loading | 0.5 % | |
| residual ripple | | |
| • maximum | 150 mV | |
| • typical | 50 mV | |
| voltage peak | | |
| • maximum | 240 mV | |
| • typical | 150 mV | |
| display version for normal operation | Green LED for 24 V OK | |
| | | |

| reamene e delevi menimerme | 4.5.0 | |
|---|---|--|
| response delay maximum | 1.5 s | |
| voltage increase time of the output voltage | 470 | |
| • typical | 170 ms | |
| output current | | |
| • rated value | 10 A | |
| rated range | 0 10 A; +45 +60 °C: Derating 2%/K | |
| supplied active power typical | 240 W | |
| bridging of equipment | Yes | |
| number of parallel-switched equipment resources for increasing | 2 | |
| the power | | |
| efficiency | | |
| efficiency in percent | 89 % | |
| power loss [W] | | |
| at rated output voltage for rated value of the output current typical | 34 W | |
| closed-loop control | | |
| | 0.2.0/ | |
| relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical | 0.3 % | |
| relative control precision of the output voltage at load step of | 2 % | |
| resistive load 10/90/10 % typical | | |
| setting time | | |
| load step 10 to 90% typical | 0.5 ms | |
| load step 90 to 10% typical | 0.7 ms | |
| protection and monitoring | | |
| design of the overvoltage protection | < 33 V | |
| property of the output short-circuit proof | Yes | |
| design of short-circuit protection | Constant current characteristic | |
| • typical | 16 A | |
| enduring short circuit current RMS value | | |
| • typical | 12.6 A | |
| safety | | |
| galvanic isolation between input and output | Yes | |
| galvanic isolation | Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 | |
| operating resource protection class | Class I | |
| leakage current | | |
| • maximum | 3.5 mA | |
| • typical | 0.8 mA | |
| protection class ID | IP20 | |
| protection class IP | 11 20 | |
| standard | | |
| · | EN 55022 Class A | |
| standard | | |
| standard • for emitted interference | EN 55022 Class A | |
| standard • for emitted interference • for mains harmonics limitation | EN 55022 Class A | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity | EN 55022 Class A | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals | EN 55022 Class A | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability | EN 55022 Class A - EN 61000-6-2 | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking | EN 55022 Class A - EN 61000-6-2 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval | EN 55022 Class A EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes 2 333 396 h | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes 2 333 396 h | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx • ATEX | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes 2 333 396 h No No | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx • ATEX • ULhazloc approval | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes 2 333 396 h No No No | |
| standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • BIS • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx • ATEX • ULhazloc approval • cCSAus, Class 1, Division 2 | EN 55022 Class A - EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No Yes; R-41183539 Yes 2 333 396 h No No No No | |

| shipbuilding approval | No | |
|---|---|--|
| Marine classification association | | |
| American Bureau of Shipping Europe Ltd. (ABS) | No | |
| French marine classification society (BV) | No | |
| Det Norske Veritas (DNV) | No | |
| Lloyds Register of Shipping (LRS) | No | |
| standards, specifications, approvals Environmental Product Dec | claration | |
| Environmental Product Declaration | Yes | |
| Global Warming Potential [CO2 eq] | | |
| • total | 1 083.3 kg | |
| during manufacturing | 19.4 kg | |
| during operation | 1 063.3 kg | |
| after end of life | 0.53 kg | |
| ambient conditions | | |
| ambient temperature | | |
| during operation | 0 60 °C; with natural convection | |
| during transport | -40 +85 °C | |
| during storage | -40 +85 °C | |
| environmental category according to IEC 60721 | Climate class 3K3, 5 95% no condensation | |
| connection method | Cilinate class cite, c co /e file collectionion | |
| | agray terminal | |
| type of electrical connection | screw terminal | |
| • at input | L, N, PE: 1 screw terminal each for 0.5 2.5 mm² single-core/finely stranded | |
| • at output | +, -: 2 screw terminals each for 0.5 2.5 mm ² | |
| for auxiliary contacts | • | |
| mechanical data | | |
| width × height × depth of the enclosure | 70 × 120 | |
| installation width × mounting height | 70 mm | |
| required spacing | | |
| • top | 50 mm | |
| • bottom | 50 mm | |
| • left | 0 mm | |
| • right | 0 mm | |
| fastening method | Snaps onto DIN rail EN 60715 35x7.5/15 | |
| standard rail mounting | Yes | |
| S7 rail mounting | No | |
| wall mounting | No | |
| housing can be lined up | Yes | |
| net weight | 0.75 kg | |
| further information internet links | , | |
| internet link | | |
| to website: Industry Mall | https://mall.industry.siemens.com | |
| • | https://siemens.com/tst | |
| to web page: selection aid TIA Selection Tool to website: Industrial communication. | http://www.siemens.com/simatic-net | |
| to website: Industrial communication to website: CAx Download Manager | | |
| to website: CAx-Download-Manager to website: Industry Online Support | http://www.siemens.com/cax | |
| to website: Industry Online Support additional information | https://support.industry.siemens.com | |
| additional information | | |
| other information | Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified) | |
| security information | Sand-mod opposition) | |
| | Signane provides products and colutions with industrial subsequently functions | |
| security information | Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are | |

no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications

| | Version | Classification |
|--------|---------|----------------|
| eClass | 14 | 27-04-07-01 |
| eClass | 12 | 27-04-07-01 |
| eClass | 9.1 | 27-04-07-01 |
| eClass | 9 | 27-04-07-01 |
| eClass | 8 | 27-04-90-02 |
| eClass | 7.1 | 27-04-90-02 |
| eClass | 6 | 27-04-90-02 |
| ETIM | 9 | EC002540 |
| ETIM | 8 | EC002540 |
| ETIM | 7 | EC002540 |
| IDEA | 4 | 4130 |
| UNSPSC | 15 | 39-12-10-04 |

Approvals Certificates

General Product Approval



Manufacturer Declaration

Declaration of Conformity





BIS CRS

Environment



last modified:

5/22/2024

